

Town of Rosendale Streetlight Assessment 2013  
Streetlight Candidates for Wattage Reduction

Pole #	CH St-Loc	District	CH Type	CH Size	Light at intersection or sharp curve?	Light by sidewalk/pedestrian traffic?	Motor vehicle traffic	Business district?	Covering intended area?	Does light make noise?	Can light size be reduced?	Light color	Glare?	Light pollution?	Light uniformity?	Light operating?	Consider eliminating?	Timer/Sensor wrong?	Notes (initial your notes)
131791	Church St/Taylor St	Twng Chg	HPS	27000	intersection	no	light	no	yes	no	yes	yellow	too bright	yes	no	yes	no	no	reduce brightness
119207	GREENKILL RD	Twng Chg	HPS	50000	intersection	no	light	no	yes	no	yes	white	too bright	no	yes	yes	no	no	
K119102	HICKORY BUSH	Twng Chg	HPS	27000	intersection	no	average	no	yes	no	yes	yellow/white	too bright	yes	yes	yes	no	no	reduce brightness
K0070574	LUCAS TPKE	Twng Chg	HPS	27000	intersection	no	heavy	no	yes	no	yes	whitish-pink	average	no	no	yes	no	no	
168009	Maple Hill/LeFever Falls	Twng Chg	HPS	16000	intersection	no	average	no	yes	no	yes	yellow/white	average	yes	yes	yes	no	no	reduce
47414	Springtown Rd/Ritters Pond	Twng Chg	HPS	27000	sharp curve	no	average	no	yes	no	yes	yellow/white	average	no	yes	yes	no	no	at Ritters Pond
k14768	Springton/Davis	Twng Chg	HPS	27000	intersection	no	light	no	yes	no	yes	yellow/white	average	no	no	yes	yes	no	this stretch of Elting Rd can have numerous lights eliminated
K0015750	HARDENBURG	Village	HPS	27000	no	yes	heavy	yes	yes	no	yes	pinkish	average	yes	yes	yes	no	no	
105408	MAIN ST	Village	HPS	16000	no	yes	heavy	yes	yes	no	yes		yes	no		yes	no	no	
105410	MAIN ST	Village	HPS	16000	yes	yes	heavy	yes	yes	no	yes	pink-orange	too bright	yes	yes	yes	no	no	height and spread of light shines in 2nd story windows of homes
105413	MAIN ST	Village	HPS	16000	yes	yes	heavy	yes	yes	no	yes	pink-orange	too bright	yes	yes	yes	no	no	height and spread of light shines in 2nd story windows.
105417	MAIN ST	Village	HPS	27000	no	yes	heavy	yes	yes	no	yes	pink-orange	too bright	yes	yes	yes	no	no	height and spread of light shines in 2nd story windows
K0065373	WEST & HILLS	Village	HPS	16000	yes	no	light	no	yes	no	yes	orange/yellow	average	no		yes	no	no	